

2020 Annual Inspection and Radiological Survey Results for the Piqua, Ohio, Decommissioned Reactor Site

August 2020



U.S. DEPARTMENT OF
ENERGY

Legacy
Management

This page intentionally left blank

Contents

Abbreviations	ii
Executive Summary	iii
1.0 Introduction	1
1.1 Background.....	1
2.0 Inspection Results	1
2.1 Exterior of the Containment Building	1
2.2 Surrounding Area	2
2.3 Interior	2
2.4 Cathodic Protection System	3
2.5 High Water Alarm System	3
2.6 Radiological Survey	4
2.6.1 Survey Results for 2020.....	4
3.0 Maintenance Action Requests	5
4.0 References	5
5.0 Photographs.....	5

Table

Table 1. Instrumentation for Radiological Survey.....	4
---	---

Appendixes

Appendix A	Site Drawings
Appendix B	2020 Piqua Annual Radiological Survey Results

Abbreviations

CFR	<i>Code of Federal Regulations</i>
cm ²	square centimeters
DOE	U.S. Department of Energy
dpm	disintegrations per minute
ft	feet
LM	Office of Legacy Management
LMS	Legacy Management Support
µrem/h	microrem per hour
OAP Room	Operating Air Pressure Room
PL	photograph location

Executive Summary

This report presents the findings of the annual inspection and radiological survey of the Piqua, Ohio, Decommissioned Reactor Site (site). In accordance with the site's Long-Term Surveillance and Maintenance Plan the facility was inspected and surveyed for radiation on June 23, 2020. The site, on the east bank of the Great Miami River in Piqua, Ohio, is in fair physical condition. No evidence of wildlife in the facility, vandalism, or trespassing was observed during this year's inspection.

The 2020 inspection was conducted safely during the COVID-19 pandemic to ensure the field inspection met the expectation of the Ohio Department of Health COVID-19 orders, and Office of Legacy Management (LM) Phase 2 COVID-19 requirements.

Radiological survey results in 2020 were consistent with the historical survey results. One direct beta radiation activity reading in a floor drain on the 56-foot level read 688 disintegrations per minute (dpm) per 100 square centimeters (cm²), which is also consistent with past results and well below the action level of 5000 dpm/100 cm².

The City of Piqua vacated the facility in the fall of 2018. LM is now responsible for facility maintenance per the contract and lease amendments. In light of the vacancy, a monthly protectiveness assessment is conducted until such time that LM determines the long-term site usage.

The four key deficiencies, noted since the 2018 inspection, remain.

1. The sump pump, which keeps water out of the basement of the Reactor Building, has been out of service since 2018. In addition, the high water alarm to the sump pump has been removed. Both of these protective assets require replacement. An assessment was released in December of 2018 that recommended reinstalling the high-water level alarm system and replacing the sump pump. Both recommendations were based on the assumption that the current decommissioned state of the facility would not change. These recommendations though are currently under deferment, until a decision has been made concerning the long-term state of the site. In the interim, since the facility is not occupied on a routine basis, the water has been shut off to prevent any spills or leaks, thereby reducing the impact of the inoperable sump pump.
2. The heat pump that heats the facility has been out of service since 2017 and needs to be repaired or replaced if the facility is to be reoccupied. Because the site is unoccupied and the utilities (electric and water) have been shut off, this deficiency does not present a protectiveness concern for the site or entombment.
3. The primary waterline break in the former reactor facility fire suppression system was repaired prior to the 2018 inspection; however, the fire suppression lines throughout the facilities and sprinkler heads remain untested. Since verification testing has not been completed, the fire suppression system has not been verified as operable. This is not a protectiveness concern as the facility is unoccupied and the water has been shut off.
4. The cathodic protection system remains inoperable due to electricity being cut off from the building. This is unlikely to have an impact on the integrity of the dome in the short-term, while a decision regarding the long-term state of the site is being made.

This page intentionally left blank

1.0 Introduction

This report presents the findings of the annual U.S. Department of Energy (DOE) inspection and radiological survey of the Piqua, Ohio, Decommissioned Reactor Site, which is assigned to the Office of Legacy Management (LM) for long-term custody and care.

Navarro Research and Engineering, Inc. (Navarro), as the Legacy Management Support (LMS) contractor, conducted the site inspection and radiological survey on June 23, 2020. The LM site manager and three Ohio Department of Health employees accompanied the inspection team. Although the City of Piqua vacated the facility in 2018, the city remains a current stakeholder, and will be sent a copy of this report including the DOE inspection report and radiological survey results.

The purpose of the inspection was to assess the general conditions of the site and to ensure that the entombment remains in a protective state until radiation limits defined in Title 10 *Code of Federal Regulations* Section 20 (10 CFR 20) have been reached. Radiological activity within the facility was also assessed against limits for occupational radiation protection defined in 10 CFR 835.

1.1 Background

The site consists of a Containment Building and an associated Auxiliary Building. Both buildings had been used by city workers as storage spaces, workshops, and offices. The city vacated the facility in 2018, and the site is currently unoccupied. LM is responsible for site maintenance and is in the process of determining what the long-term state of the site.

Utilities (electric and water) to the Piqua facility were turned off in 2019 to facilitate an asbestos abatement project and both remain off. The 2020 inspection was conducted using flashlights in areas where natural light was not available. This condition limited photos taken for the inspection to outside areas or areas in the Auxiliary Building near windows.

2.0 Inspection Results

Features discussed in this report are shown on the attached site drawings (Appendix A). Photographs to support specific observations are identified in the text and on the site drawings by photograph location (PL) numbers.

2.1 Exterior of the Containment Building

The Containment Building exterior was refurbished circa 1995. The building's exterior surface is in overall good condition, but the paint is fading and beginning to peel in a few areas (PL-1). Some exterior electrical safety concerns identified in the 2015 site utility assessment (e.g., exposed exterior electrical wiring, broken conduits, and dismantled outlets) remain, electric power to the facility has been turned off. For instance, there is exposed conduit outside the Containment Building. The break in the fire suppression line was repaired by the city in 2018, but the fire suppression system itself (e.g., sprinkler heads) was not verified as operable. Since verification testing has not been completed, the fire suppression system is considered inoperable.

2.2 Surrounding Area

The area surrounding the site was visually observed. The city's wastewater expansion project (located southeast of the site) was mostly completed. The road leading to the wastewater plant facility was recently repaved (PL-2). A new retaining wall was constructed between the treatment plant expansion and the Auxiliary Building (PL-3). No changes that could impact the integrity of the site or the entombment were observed.

2.3 Interior

Inspectors looked for evidence of structural deterioration and entombment degradation. Concerns noted in previous inspections that are not related to structural deterioration and entombment degradation remain unchanged (e.g., peeling lead-based paint, falling plaster, and deteriorating pipe insulation with asbestos containing material). It should be noted that only those inspection items that could potentially compromise the entombment will be addressed since the long-term state of the facility is currently being evaluated.

56-foot level: The 56-foot (ft) level is the lowest level of the Containment Building. Paint flakes continue to fall from the interior walls onto the floors—a condition that remains unchanged from previous inspections. Paint in the facility is lead based (DOE 2017).

The 2016 site inspection report noted that a vertical drainpipe on the northwest wall of the Containment Building's 56 ft level had developed a small crack and split open. Inspectors traced the pipe to the 100 ft level, where it connects to a floor drain. Inspectors noted during this year's inspection that the cracked pipe and its surrounding area were dry. Because the floor drain is in part of the 100 ft level that does not encounter water, it is unlikely that water will enter the pipe from the 100 ft level. Inspectors will continue to check for water around the exterior of this pipe on the 56 ft level.

A sump pump is located in the floor of the 56 ft level. LM personnel were notified on April 5, 2018, that the sump pump was not operational. The sump pump was pulled and surveyed for radiological activity on May 23, 2018. No radiological activity was detected on the pump, and it was identified as eligible for disposal as sanitary waste. A 2018 assessment recommended that the sump pump be replaced (DOE 2018). Replacement of the sump pump is currently on hold, until a decision has been made concerning the long-term state of the site. The water to the facility has been shut off, greatly reducing the potential need for sump pump operation. During the June 2020 inspection, the sump pump was dry.

79-foot level: Interior conditions noted in the Auxiliary Building in previous inspections (e.g., broken plaster, peeling paint, and water damage) remain unchanged. From 2013 to 2018, the city had used several of the rooms on this level of the Auxiliary Building for storage.

Newly installed roof fabric continues to eliminate water seepage that was noted in past inspections in the Auxiliary Building along the ceiling seam of the Operating Air Pressure (OAP) Room and Room B-1, which is directly below the OAP Room. The southwest wall of both rooms is the curved wall of the Containment Building. The evidence of previous water seepage is noted on the 79 ft level site inspection map and will continue to be monitored in future inspections.

83-foot level: No issues identified.

100-foot level: The concrete around the southwest air lock of the Containment Building remains in need of repair. Numerous cracks are present, and some small pieces of concrete are falling off. LM is determining a path forward for the facility that will evaluate the repair of the concrete around the air lock (PL-4).

111-foot level: No concerns.

121-foot level (Auxiliary Building rooftop): The roof fabric of the Auxiliary Building was replaced in 2016 and remains in excellent condition. Auxiliary Building roof drains also were in excellent condition.

2.4 Cathodic Protection System

A cathodic protection system was installed on the Containment Building during construction of the facility to protect the 3/8 inch steel shell that surrounds the exterior of the below grade portion of the reactor shell. The system consists of 10 carbon (graphite) electrodes buried radially approximately 10 to 20 ft from the building foundation and a rectifier unit that provides direct-current electrical power. The rectifier unit is mounted in the break room south of and outside the air lock on the 100 ft level of the Auxiliary Building. Each carbon electrode is 3 inches in diameter and 60 inches long. The electrodes are connected to the rectifier unit by a header cable; splices are protected in flush-mounted boxes. A structure contact point for monitoring potential can be found on the shell associated with each electrode; some of the contact points also have cables remaining from an abandoned zinc anode protection system. The system includes reference electrodes and test holes.

The cathodic protection system was checked by a qualified service provider in 2016, and all electrodes were replaced. The system is currently turned off because electric service to the facility was turned off in 2019. An assessment conducted by LM in 2018 recommended that the system be maintained until January 2041 (DOE 2018). LM is evaluating the continued need for the cathodic protection system, pending a decision concerning the long-term state of the facility.

2.5 High Water Alarm System

An alarm system is installed in the sump on the 56 ft level of the Containment Building to detect high water levels before they reach the bottom of the entombment. This system was designed to prevent immersion and accelerated corrosion of the entombment. The alarm would trigger when the sump pump filled to a level near overflow, alerting personnel to both high water and possible sump pump failure. The alarm would register in the Auxiliary Building on the Supervisory Control and Data Acquisition System, which was monitored 24 hours a day. The alarm system was included in the monthly building inspection that had historically been conducted by the City of Piqua.

In 2018, inspectors were informed that the high water alarm to the sump system was removed prior to 2013 when the city's power system personnel vacated the building. A 2018 assessment recommended that the high water alarm system be reinstalled (DOE 2018). LM is evaluating the

continued need for the high water alarm, pending a decision concerning the long-term state of the facility.

2.6 Radiological Survey

LMS contractor staff performed the annual radiological survey inside the Containment Building, the Auxiliary Building, and in exterior areas; 106 sample locations were checked for both removable and direct surface contamination using direct measurements and smears to detect alpha, beta, and gamma radiation activity. Gamma radiation exposure rates also were measured.

In 2009, the city modified Rooms R-6 and R-7. Modifications included the elimination of an air duct (a component of the heating, ventilation, and air-conditioning system) connecting the two rooms. Smear sample No. 46 was collected from this air duct before 2009. Survey location No. 46 is now on the floor of Room R-7 in front of the former air duct.

Table 1 presents information about the instrumentation used to perform the survey.

Table 1. Instrumentation for Radiological Survey

Type of Measurement	Radiation	Detector Serial Number	Meter Serial Number	Background	Efficiency Factor	Critical Value
Direct activity	Alpha	Ludlum 43-89 PR184184	Ludlum 2360 177157	2.0 cpm/ 100 cm ²	17% efficient	29
Direct activity	Beta	Ludlum 43-89 PR184184	Ludlum 2360 177157	144 cpm/ 100 cm ²	40% efficient	73
Exposure rate	Gamma	NA	Thermo FH40 GL 016191	5 µrem/h	NA	NA
Removable activity	Alpha	Ludlum 43-10-1 PR362456	Ludlum 2929 329909	0.4 cpm	32% efficient	3
Removable activity	Beta	Ludlum 43-10-1 PR362456	Ludlum 2929 329909	38.0 cpm	39% efficient	27

Abbreviations:

cm² = square centimeters
 cpm = counts per minute
 dpm = disintegrations per minute
 µrem/h = microrem per hour
 NA = not applicable or accessible

2.6.1 Survey Results for 2020

Direct measurements and smear surveys were collected at 106 locations in 2020, and results were consistent with past years. Survey locations are provided in Appendix A. Six survey locations had removable beta contamination above the critical value level but below the 10 CFR 835 surface contamination limit values. The highest removable surface contamination value was 51 dpm/100 cm², substantially below the 10 CFR 835 beta removable surface contamination limit value of 1000 dpm/100 cm². Specific results are provided in Appendix B.

The results of both the direct and smear surveys were all lower than 10 CFR 835 limits for surface contamination. Only one location (floor drain location No. 16 on the 56 ft level) had a direct reading above the critical value of 73 dpm/100 cm² for beta. That direct reading was

688 dpm/100 cm² for beta, which is well below the 10 CFR 835 limit of 5000 dpm/100 cm² for beta. The smear from this location indicated that no removable activity was present. All direct readings for alpha were less than the critical value of 29 dpm/100 cm². The 10 CFR 835 limit for alpha is 500 dpm/100 cm².

Gamma radiation exposure rates also were measured during the survey. Reading locations are provided in Appendix A. The highest gamma radiation exposure rate measured in the facility (100 ft level of the Auxiliary Building) in 2019 was 10 microrem per hour (µrem/h). This was 5 µrem/h above the outside background measurement of 5 µrem/h. The 5 µrem/h above background is significantly lower than the 10 CFR 835 limit for a radiation area of 5000 µrem/h.

3.0 Maintenance Action Requests

Maintenance activities are on hold pending a decision on the long-term state of the facility unless maintenance is needed ensure the immediate protectiveness of the entombment.

4.0 References

DOE (U.S. Department of Energy), 2017. *Decommissioned Reactor Site, Piqua, Ohio, Hazardous Materials Survey*, Resource International Incorporated, January.

DOE (U.S. Department of Energy), 2018. *Piqua, Ohio, Decommissioned Reactor Site Water Control System Assessment*, LMS/PIQ/S22314, U.S. Department of Energy, December 2018.

5.0 Photographs

Photograph Location Number	Azimuth	Elevation Level (in feet)	Photograph Description
PL-1	215	100	Containment Building
PL-2	170	100	New Paving to Water Treatment Plant
PL-3	30	100	New Retaining Wall
PL-4	360	100	Air Lock



PL-1. Containment Building



PL-2. New Paving to Water Treatment Plant



PL-3. New Retaining Wall



PL-4. Air Lock

This page intentionally left blank

Appendix A
Site Drawings

This page intentionally left blank




Figure A-1. 2019 Annual Inspection and Radiological Survey Results, Piqua, Ohio, Decommissioned Reactor Site




Figure A-2. Annual Radiological Survey Results Piqua, Ohio, Decommissioned Reactor Site Plan, 56-Foot Level


SMEAR/DIRECT LOCATIONS ON THE 79-FOOT LEVEL IN CONTAINMENT STRUCTURE

- (24) FLOOR
- (25) FLOOR
- (26) FLOOR
- (27) FLOOR
- (111) IN HVAC DUCT 74-FOOT LEVEL

"OAP" (OPERATING AIR PRESSURE) ROOM REMODELED IN 2009. PAINTED AND SHELVES WERE ADDED.



KEY:

- NO. = GENERAL AREA EXPOSURE RATE ($\mu\text{rem/h}$)
- (NO) = SMEAR/DIRECT LOCATION
- [R-4] = ROOM NUMBER



SMEAR/DIRECT LOCATIONS ON THE 79-FOOT LEVEL IN AUX. BLDG.

- (51) FLOOR
- (52) FLOOR
- (53) FLOOR
- (54) ON DRAIN
- (55) FLOOR
- (56) FLOOR
- (57) FLOOR
- (58) ON DRAIN
- (59) FLOOR
- (60) FLOOR
- (61) ON DRAIN
- (62) ON SUMP COVER
- (63) PUMP
- (64) FLOOR UNDER TANK
- (65) FLOOR
- (66) FLOOR
- (67) INSIDE HVAC ON FLOOR
- (68) FLOOR
- (69) FLOOR--89' LEVEL OAP ROOM



ANNUAL INSPECTION AND RADIOLOGICAL SURVEY CONDUCTED JUNE 23, 2020

	Legacy Management GRAND JUNCTION, COLORADO	Work Performed Under DOE Contract No. DE-LM0000421 NAVARRO Research and Engineering, Inc. Contractor to the U.S. Department of Energy Office of Legacy Management
	2020 ANNUAL INSPECTION AND RADIOLOGICAL SURVEY RESULTS PIQUA DECOMMISSIONED REACTOR SITE PIQUA, OHIO	
DATE PREPARED: AUGUST 11, 2020	FILENAME: S2874700	

PLAN - 79 FOOT LEVEL

M: \LTS\111\0027\03\S28747\S2874700-R1.DWG 8/11/2020 10:10:19 AM atencioj

Figure A-3. Annual Radiological Survey Results, Piqua, Ohio, Decommissioned Reactor Site Plan, 79-Foot Level




Figure A-4. Annual Radiological Survey Results, Piqua, Ohio, Decommissioned Reactor Site Plan, 83-Foot Level




Figure A-5. Annual Radiological Survey Results, Piqua, Ohio, Decommissioned Reactor Site Plan, 100-Foot Level






Figure A-6. Annual Radiological Survey Results, Piqua, Ohio, Decommissioned Reactor Site Plan, 111-Foot Level

SMEAR/DIRECT LOCATIONS ON THE
121-FOOT LEVEL IN THE AUX. BLDG.

- ⑦①-FLOOR
- ⑦②-FLOOR
- ⑦③-FLOOR
- ⑦④-FLOOR
- ⑦⑤-FLOOR




PLAN - 121 FOOT LEVEL



KEY:

- NO. = GENERAL AREA EXPOSURE RATE ($\mu\text{rem/h}$)
- ⑦① = SMEAR/DIRECT LOCATION
- R-4 = ROOM NUMBER



ANNUAL INSPECTION AND
RADIOLOGICAL SURVEY CONDUCTED
JUNE 23, 2020

 U.S. DEPARTMENT OF ENERGY Legacy Management GRAND JUNCTION, COLORADO	 Work Performed Under DOE Contract No. DE-LM0000421 Navarro Research and Engineering, Inc. Contractor to the U.S. Department of Energy Office of Legacy Management
DATE PREPARED: AUGUST 11, 2020	FILENAME: S2874700

M:\LTS\111\0027\03\S28747\S2874700-R1.DWG 8/11/2020 10:10:19 AM atencioj

Figure A-7. Annual Radiological Survey Results, Piqua, Ohio, Decommissioned Reactor Site Plan, 121-Foot Level

This page intentionally left blank

Appendix B

2020 Piqua Annual Radiological Survey Results

This page intentionally left blank

Radiological Survey Map

Radiological Survey Number: 200623-001

Page 1 of 14

Purpose: 2020 Annual Piqua Radiological Survey

Truck #: N/A

Trailer #: N/A

RWP number: N/A

Time: 3:00 PM

Date: 6/23/2020

Site name: Piqua

Location: Various

RCT (printed): L. Oeffner Jr.

Reviewer signature: SCOTT NEWSOM (Affiliate)

Digitally signed by SCOTT NEWSOM (Affiliate)
Date: 2020.08.13 15:47:11 -0600

Date:

Counting Instruments:	Instrument 1	Instrument 2	Instrument 3	Radiation Instruments:	Instrument 4
Instrument/probe model:	Lud-2929/43-10-1	N A	Lud-2360/43-89	Instrument/probe model:	Thermo FH40G-L
Instrument serial number:	329909		177157	Instrument serial number:	16191
Probe serial number:	PR362456		PR184184	Probe serial number:	N/A
Calibration due:	5/27/2021		5/27/2021	Calibration due:	5/27/2021
Efficiency:	α 0.32 β 0.39		α 0.17 β 0.40	Background (dose rate):	5 microRem/hr
Background (cpm):	α 0.40 β 38	α 2 β 144	Other info (as needed):	none	
S _c (dpm/100cm ²):	α 3 β 27	α 29 β 73			
Area probe correction factor:	1.0		1.0		

Surface Contamination and Radiation Survey Results

Item Surveyed / Map Location	Counting Inst. No. Used	Smear Survey (Instrument 1 or 2)						Direct Survey (Instrument 3)						Exposure Rate Survey
		Gross Counts		Net Counts		Activity		Gross Counts		Net Counts		Activity		
		Alpha cpm	Beta/gamma cpm	Alpha cpm	Beta/gamma cpm	Alpha dpm/100cm ²	Beta/gamma dpm/100cm ²	Alpha cpm	Beta/gamma cpm	Alpha cpm	Beta/gamma cpm	Alpha dpm/100cm ²	Beta/gamma dpm/100cm ²	
1, N/A														
2, N/A														
3, N/A														
4, N/A				N										
5, N/A					A									
6, N/A														
7, N/A										N				
8, N/A														
9, floor	1	0	39	-0.4	1.0	< Sc	< Sc					A		
10, floor	1	0	40	-0.4	2.0	< Sc	< Sc							
11, floor	1	0	36	-0.4	-2.0	< Sc	< Sc							
12, floor	1	0	37	-0.4	-1.0	< Sc	< Sc							
13, floor	1	0	33	-0.4	-5.0	< Sc	< Sc							
14, floor	1	1	36	0.6	-2.0	< Sc	< Sc							
15, floor	1	0	35	-0.4	-3.0	< Sc	< Sc							
16, drain	1	0	40	-0.4	2.0	< Sc	< Sc	3	419	1.0	275.0	< Sc	688	

RCT signature: LAWRENCE OEFFNER (Affiliate)

Digitally signed by LAWRENCE OEFFNER (Affiliate)
Date: 2020.08.12 14:47:54 -0400

File index number:

Radiological Survey Map

Radiological Survey Number: 200623-001

Page 2 of 14

Surface Contamination and Radiation Survey Results															
Item Surveyed / Map Location	Counting Inst. No. Used	Smear Survey (Instrument 1 or 2)						Direct Survey (Instrument 3)						Exposure Rate Survey	
		Gross Counts		Net Counts		Activity		Gross Counts		Net Counts		Activity			
		Alpha cpm	Beta/gamma cpm	Alpha cpm	Beta/gamma cpm	Alpha dpm/100cm ²	Beta/gamma dpm/100cm ²	Alpha cpm	Beta/gamma cpm	Alpha cpm	Beta/gamma cpm	Alpha dpm/100cm ²	Beta/gamma dpm/100cm ²		
17, floor	1	0	41	-0.4	3.0	< Sc	< Sc								
18, pedestal	1	0	47	-0.4	9.0	< Sc	< Sc								
19, drain	1	0	36	-0.4	-2.0	< Sc	< Sc								
20, grating	1	0	37	-0.4	-1.0	< Sc	< Sc								
21, vent	1	0	33	-0.4	-5.0	< Sc	< Sc								
22, drain	1	0	38	-0.4	0.0	< Sc	< Sc								
23, drain	1	0	40	-0.4	2.0	< Sc	< Sc								
24, floor	1	0	33	-0.4	-5.0	< Sc	< Sc								
25, floor	1	0	47	-0.4	9.0	< Sc	< Sc								
26, floor	1	0	33	-0.4	-5.0	< Sc	< Sc								
27, floor	1	0	37	-0.4	-1.0	< Sc	< Sc								
28, HVAC duct	1	1	34	0.6	-4.0	< Sc	< Sc								
29, grating	1	0	48	-0.4	10.0	< Sc	< Sc								
30, pipe	1	0	41	-0.4	3.0	< Sc	< Sc								
31, duct	1	0	42	-0.4	4.0	< Sc	< Sc								
32, grating	1	0	33	-0.4	-5.0	< Sc	< Sc								

N
A

Applicable Surface Contamination Limits			
Check one for alpha, one for beta.			
Alpha (removable/total)	<input type="checkbox"/> 1000/5000	<input type="checkbox"/> 200/1000	<input checked="" type="checkbox"/> 20/500
Beta (removable/total)	<input checked="" type="checkbox"/> 1000/5000	<input type="checkbox"/> 200/1000	

Activity Equation
Gross count minus BKGD count = Net count
Net count/Eff = dpm
Dpm x Area Probe Correction Factor (APCF) = dpm/100cm ²

APCE
44-9 = 6.5
FHZ 732 (GM) = 6.5
43-10-1 = 1

Remarks:
 HVAC equipment removed at locations 1-5, standing water from rain on roof, at locations 6-8, therefore no smears or direct readings taken. *No direct, static measurements taken, as there were no obvious increase in audible count rates, except location #16.


Radiological Survey Map

Radiological Survey Number: 200623-001

Page 3 of 14

Surface Contamination and Radiation Survey Results

Item Surveyed / Map Location	Counting Inst. No. Used	Smear Survey (Instrument 1 or 2)						Direct Survey (Instrument 3)						Exposure Rate Survey
		Gross Counts		Net Counts		Activity		Gross Counts		Net Counts		Activity		
		Alpha cpm	Beta/gamma cpm	Alpha cpm	Beta/gamma cpm	Alpha dpm/100cm ²	Beta/gamma dpm/100cm ²	Alpha cpm	Beta/gamma cpm	Alpha cpm	Beta/gamma cpm	Alpha dpm/100cm ²	Beta/gamma dpm/100cm ²	
33, pedestal	1	1	45	0.6	7.0	< Sc	< Sc							
34, drain	1	0	36	-0.4	-2.0	< Sc	< Sc							
35, drain	1	1	37	0.6	-1.0	< Sc	< Sc							
36, pedestal	1	1	46	0.6	8.0	< Sc	< Sc							
37, stairwell	1	0	49	-0.4	11.0	< Sc	28							
38, floor	1	0	34	-0.4	-4.0	< Sc	< Sc							
39, floor	1	1	41	0.6	3.0	< Sc	< Sc							
40, floor	1	0	39	-0.4	1.0	< Sc	< Sc							
41, floor	1	0	32	-0.4	-6.0	< Sc	< Sc							
42, floor	1	0	33	-0.4	-5.0	< Sc	< Sc							
43, floor	1	0	39	-0.4	1.0	< Sc	< Sc							
44, floor	1	0	41	-0.4	3.0	< Sc	< Sc							
45, drain	1	1	41	0.6	3.0	< Sc	< Sc							
46, floor	1	0	40	-0.4	2.0	< Sc	< Sc							
47, floor	1	0	37	-0.4	-1.0	< Sc	< Sc							
48, floor	1	0	41	-0.4	3.0	< Sc	< Sc							



Applicable Surface Contamination Limits
Check one for alpha, one for beta.

Alpha (removable/total)	<input type="checkbox"/> 1000/5000	<input type="checkbox"/> 200/1000	<input checked="" type="checkbox"/> 20/500
Beta (removable/total)	<input checked="" type="checkbox"/> 1000/5000	<input type="checkbox"/> 200/1000	

Activity Equation

Gross count minus BKGD count = Net count
 Net count/Eff = dpm
 Dpm x Area Probe Correction Factor (APCF) = dpm/100cm²

APCE

44-9 = 6.5
 FHZ 732 (GM) = 6.5
 43-10-1 = 1

Remarks:
 * No direct, static measurements taken, as there were no obvious increase in audible count rates.

Radiological Survey Map

Radiological Survey Number: 200623-001

Page 4 of 14

Surface Contamination and Radiation Survey Results														
Item Surveyed / Map Location	Counting Inst. No. Used	Smear Survey (Instrument 1 or 2)						Direct Survey (Instrument 3)						Exposure Rate Survey
		Gross Counts		Net Counts		Activity		Gross Counts		Net Counts		Activity		
		Alpha cpm	Beta/gamma cpm	Alpha cpm	Beta/gamma cpm	Alpha dpm/100cm ²	Beta/gamma dpm/100cm ²	Alpha cpm	Beta/gamma cpm	Alpha cpm	Beta/gamma cpm	Alpha dpm/100cm ²	Beta/gamma dpm/100cm ²	
49, floor	1	0	33	-0.4	-5.0	< Sc	< Sc							
50, airlock	1	0	44	-0.4	6.0	< Sc	< Sc							
51, floor	1	0	45	-0.4	7.0	< Sc	< Sc							
52, floor	1	0	58	-0.4	20.0	< Sc	51							
53, floor	1	0	45	-0.4	7.0	< Sc	< Sc							
54, drain	1	0	41	-0.4	3.0	< Sc	< Sc							
55, floor	1	0	35	-0.4	-3.0	< Sc	< Sc							
56, floor	1	0	39	-0.4	1.0	< Sc	< Sc							
57, floor	1	1	39	0.6	1.0	< Sc	< Sc							
58, drain	1	0	48	-0.4	10.0	< Sc	< Sc							
59, floor	1	0	36	-0.4	-2.0	< Sc	< Sc							
60, floor	1	0	43	-0.4	5.0	< Sc	< Sc							
61, drain	1	0	43	-0.4	5.0	< Sc	< Sc							
62, sump cover	1	1	36	0.6	-2.0	< Sc	< Sc							
63, pump	1	0	49	-0.4	11.0	< Sc	28							
64, floor	1	0	37	-0.4	-1.0	< Sc	< Sc							

N
A

Applicable Surface Contamination Limits			
Check one for alpha, one for beta.			
Alpha (removable/total)	<input type="checkbox"/> 1000/5000	<input type="checkbox"/> 200/1000	<input checked="" type="checkbox"/> 20/500
Beta (removable/total)	<input checked="" type="checkbox"/> 1000/5000	<input type="checkbox"/> 200/1000	

Activity Equation
Gross count minus BKGD count = Net count
Net count/Eff = dpm
Dpm x Area Probe Correction Factor (APCF) = dpm/100cm ²

APCE
44-9 = 6.5
FHZ 732 (GM) = 6.5
43-10-1 = 1

Remarks:
*No direct, static measurements taken, as there were no obvious increase in audible count rates.

Radiological Survey Map

Radiological Survey Number: 200623-001

Page 5 of 14

Surface Contamination and Radiation Survey Results														
Item Surveyed / Map Location	Counting Inst. No. Used	Smear Survey (Instrument 1 or 2)						Direct Survey (Instrument 3)						Exposure Rate Survey
		Gross Counts		Net Counts		Activity		Gross Counts		Net Counts		Activity		
		Alpha cpm	Beta/gamma cpm	Alpha cpm	Beta/gamma cpm	Alpha dpm/100cm ²	Beta/gamma dpm/100cm ²	Alpha cpm	Beta/gamma cpm	Alpha cpm	Beta/gamma cpm	Alpha dpm/100cm ²	Beta/gamma dpm/100cm ²	
65, floor	1	1	38	0.6	0.0	< Sc	< Sc							
66, floor	1	0	36	-0.4	-2.0	< Sc	< Sc							
67, HVAC floor	1	0	40	-0.4	2.0	< Sc	< Sc							
68, floor	1	0	41	-0.4	3.0	< Sc	< Sc							
69, floor	1	0	38	-0.4	0.0	< Sc	< Sc							
70, floor	1	0	37	-0.4	-1.0	< Sc	< Sc							
71, floor	1	0	38	-0.4	0.0	< Sc	< Sc							
72, floor	1	0	41	-0.4	3.0	< Sc	< Sc							
73, floor	1	0	40	-0.4	2.0	< Sc	< Sc							
74, floor	1	0	45	-0.4	7.0	< Sc	< Sc							
75, floor	1	0	35	-0.4	-3.0	< Sc	< Sc							
76, floor	1	1	47	0.6	9.0	< Sc	< Sc							
77, floor	1	0	36	-0.4	-2.0	< Sc	< Sc							
78, floor	1	0	50	-0.4	12.0	< Sc	31							
79, floor	1	0	33	-0.4	-5.0	< Sc	< Sc							
80, vent duct	1	0	40	-0.4	2.0	< Sc	< Sc							

N
A

Applicable Surface Contamination Limits			
Check one for alpha, one for beta.			
Alpha (removable/total)	<input type="checkbox"/> 1000/5000	<input type="checkbox"/> 200/1000	<input checked="" type="checkbox"/> 20/500
Beta (removable/total)	<input checked="" type="checkbox"/> 1000/5000	<input type="checkbox"/> 200/1000	

Activity Equation
Gross count minus BKGD count = Net count
Net count/Eff = dpm
Dpm x Area Probe Correction Factor (APCF) = dpm/100cm ²

APCE
44-9 = 6.5
FHZ 732 (GM) = 6.5
43-10-1 = 1

Remarks:
*No direct, static measurements taken, as there were no obvious increase in audible count rates.

Radiological Survey Map

Radiological Survey Number: 200623-001

Page 6 of 14

Surface Contamination and Radiation Survey Results														
Item Surveyed / Map Location	Counting Inst. No. Used	Smear Survey (Instrument 1 or 2)						Direct Survey (Instrument 3)						Exposure Rate Survey
		Gross Counts		Net Counts		Activity		Gross Counts		Net Counts		Activity		
		Alpha cpm	Beta/gamma cpm	Alpha cpm	Beta/gamma cpm	Alpha dpm/100cm ²	Beta/gamma dpm/100cm ²	Alpha cpm	Beta/gamma cpm	Alpha cpm	Beta/gamma cpm	Alpha dpm/100cm ²	Beta/gamma dpm/100cm ²	
81, floor	1	1	49	0.6	11.0	< Sc	28							
82, floor	1	0	32	-0.4	-6.0	< Sc	< Sc							
83, floor	1	0	29	-0.4	-9.0	< Sc	< Sc							
84, floor	1	0	28	-0.4	-10.0	< Sc	< Sc							
85, floor	1	0	35	-0.4	-3.0	< Sc	< Sc							
86, drain	1	0	36	-0.4	-2.0	< Sc	< Sc							
87, floor	1	0	40	-0.4	2.0	< Sc	< Sc							
88, drain	1	0	31	-0.4	-7.0	< Sc	< Sc							
89, floor	1	0	45	-0.4	7.0	< Sc	< Sc							
90, floor	1	0	38	-0.4	0.0	< Sc	< Sc							
91, floor	1	0	34	-0.4	-4.0	< Sc	< Sc							
92, floor	1	0	45	-0.4	7.0	< Sc	< Sc							
93, floor	1	0	44	-0.4	6.0	< Sc	< Sc							
94, floor	1	0	43	-0.4	5.0	< Sc	< Sc							
95, floor	1	0	39	-0.4	1.0	< Sc	< Sc							
96, floor	1	0	41	-0.4	3.0	< Sc	< Sc							

N
A

Applicable Surface Contamination Limits			
Check one for alpha, one for beta.			
Alpha (removable/total)	<input type="checkbox"/> 1000/5000	<input type="checkbox"/> 200/1000	<input checked="" type="checkbox"/> 20/500
Beta (removable/total)	<input checked="" type="checkbox"/> 1000/5000	<input type="checkbox"/> 200/1000	

Activity Equation
Gross count minus BKGD count = Net count
Net count/Eff = dpm
Dpm x Area Probe Correction Factor (APCF) = dpm/100cm ²

APCE
44-9 = 6.5
FHZ 732 (GM) = 6.5
43-10-1 = 1

Remarks:
 *No direct, static measurements taken, as there were no obvious increase in audible count rates.

Radiological Survey Map

Radiological Survey Number: 200623-001

Page 7 of 14

Surface Contamination and Radiation Survey Results														
Item Surveyed / Map Location	Counting Inst. No. Used	Smear Survey (Instrument 1 or 2)						Direct Survey (Instrument 3)						Exposure Rate Survey
		Gross Counts		Net Counts		Activity		Gross Counts		Net Counts		Activity		
		Alpha cpm	Beta/gamma cpm	Alpha cpm	Beta/gamma cpm	Alpha dpm/100cm ²	Beta/gamma dpm/100cm ²	Alpha cpm	Beta/gamma cpm	Alpha cpm	Beta/gamma cpm	Alpha dpm/100cm ²	Beta/gamma dpm/100cm ²	
97, floor	1	0	37	-0.4	-1.0	< Sc	< Sc							
98, floor	1	0	49	-0.4	11.0	< Sc	28							
99, floor	1	0	44	-0.4	6.0	< Sc	< Sc							
100, floor	1	0	33	-0.4	-5.0	< Sc	< Sc							
101, floor	1	0	35	-0.4	-3.0	< Sc	< Sc							
102, floor	1	0	38	-0.4	0.0	< Sc	< Sc							
103, floor	1	0	35	-0.4	-3.0	< Sc	< Sc							
104, drain	1	0	42	-0.4	4.0	< Sc	< Sc							
105, drain	1	0	39	-0.4	1.0	< Sc	< Sc							
106, floor	1	0	33	-0.4	-5.0	< Sc	< Sc							
107, wall	1	0	37	-0.4	-1.0	< Sc	< Sc							
108, floor	1	0	43	-0.4	5.0	< Sc	< Sc							
109, floor	1	0	37	-0.4	-1.0	< Sc	< Sc							
110, floor	1	0	44	-0.4	6.0	< Sc	< Sc							
111, duct	1	0	35	-0.4	-3.0	< Sc	< Sc							
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A							

N
A


Applicable Surface Contamination Limits			
Check one for alpha, one for beta.			
Alpha (removable/total)	<input type="checkbox"/> 1000/5000	<input type="checkbox"/> 200/1000	<input checked="" type="checkbox"/> 20/500
Beta (removable/total)	<input checked="" type="checkbox"/> 1000/5000	<input type="checkbox"/> 200/1000	

Activity Equation
Gross count minus BKGD count = Net count
Net count/Eff = dpm
Dpm x Area Probe Correction Factor (APCF) = dpm/100cm ²

APCE
44-9 = 6.5
FHZ 732 (GM) = 6.5
43-10-1 = 1

Remarks:
*No direct, static measurements taken, as there were no obvious increase in audible count rates.


8 of 14
200623-001



ANNUAL INSPECTION AND
RADIOLOGICAL SURVEY CONDUCTED
JUNE 23, 2020

 U.S. DEPARTMENT OF ENERGY Legacy Management BRAND JACOBS, BELLEVILLE	 RAYTHEON Raytheon Research and Engineering, Inc. A Raytheon Company
DATE PREPARED: JULY 2, 2020	FILENAME: S2874700


M:\LTS\111\0027\03\S28747\S2874700-R1.DWG 7/23/2020 9:18:32 PM atencioj




M:\LTS\111\0027\03\S28747\S2874700-R1.DWG 7/23/2020 9:16:32 PM atencia]

ANNUAL INSPECTION AND RADIOLOGICAL SURVEY CONDUCTED JUNE 23, 2020

ENERGY Legacy Management	RAVARD Research, Analysis, and Consulting, Inc.
2020 ANNUAL INSPECTION AND RADIOLOGICAL SURVEY RESULTS	
PIQUA DECOMMISSIONED REACTOR SITE	
PIQUA, OHIO	
DATE PREPARED: JUNE 29, 2020	FILENAME: S2874700






ANNUAL INSPECTION AND
RADIOLOGICAL SURVEY CONDUCTED
JUNE 23, 2020

2020 ANNUAL INSPECTION AND RADIOLOGICAL SURVEY RESULTS PIQUA DECOMMISSIONED REACTOR SITE PIQUA, OHIO		
DATE PREPARED: JUNE 29, 2020	FILENAME: S2874700	


M:\LTS\111\0027\03\S28747\S2874700-R1.DWG 7/23/2020 9:16:32 PM atencioj



M:\LTS\111\0027\03\S28747\S2874700-R1.DWG 7/8/2020 8:28:05 AM atencloj

SMEAR/DIRECT LOCATIONS ON THE
121-FOOT LEVEL IN THE AUX. BLDG.



- 70-FLOOR
- 71-FLOOR
- 72-FLOOR
- 73-FLOOR
- 74-FLOOR
- 75-FLOOR



PLAN - 121 FOOT LEVEL

KEY:

- ND = GENERAL AREA EXPOSURE RATE ($\mu\text{rem/h}$)
- 70-75 = SMEAR/DIRECT LOCATION
- 301-304 = ROOM NUMBER



ANNUAL INSPECTION AND
RADIOLOGICAL SURVEY CONDUCTED
JUNE 23, 2020

	Legoy Management <small>AN OGDON COMPANY</small>		<small>Not Permitted Under DOT Standard No. 49-1030001</small> Hazardous Research and Engineering, Inc. <small>Contractors for the Environmental and Occupational Safety</small>
			2020 ANNUAL INSPECTION AND RADIOLOGICAL SURVEY RESULTS FIQUA DECOMMISSIONED REACTOR SITE PIQUA, OHIO
DATE PREPARED: JUNE 29, 2020	FILENAME: S2874700		